

3.3 Cleaning the fans

3.5 Other

3.4 Cleaning the heat exchanger

## SERVICE PROTOCOL - Air handling units for commercial buildings

Customer:		Service carried out by:
Model:		Date:
Serial number:		Signature:
		ı
Service must be carr	ied out at	least once a year
Visual check	Performed	Comment/Action
1.1 Condition of gaskets		
1.2 Seals on doors		
1.3 Condition of brushes and rotor belt		
1.4 Condition of rotor motor		
1.5 Rotor blades		
1.6 Condition of fans, hoses and cables		
1.7 Other hoses and cables		
<ul><li>1.8 Filter change interval (sufficient)</li><li>1.9 Other</li></ul>		
1.9 Other		
Function check	Performed	Comment/Action
2.1 Read off target value and compare with		
commissioning report		
2.2 Review the time channels		
2.3 Heating sequence		
2.4 Valve motor and circulation pump, water heating		
2.5 Return water sensor/frost guard		
2.6 Cooling sequence		
2.7 Valve motor and circulation pump, cooling		
2.8 Outdoor air/exhaust damper		
2.9 External accessories, e.g. pressure sensor,		
CO <sub>2</sub> sensor, etc.		
2.9.1		
2.9.2		
2.9.3	1	
2.9.4		
2.9.4 2.9.5		
2.9.4		
2.9.4 2.9.5		
2.9.4 2.9.5	Performed	Comment/Action
2.9.4 2.9.5 2.10 Other	Performed	Comment/Action