

# CERTIFICATE FI/40372/M2

Our Ref. HEL-CERT190900585-05



**Product** Powered roof ventilator  
**Type** ECo110 FLOW, ECo125 FLOW, ECo160 FLOW  
**Trademark** VILPE  
**Certificate Holder** VILPE Oy  
Kauppatie 9  
FI-65610, Mustasaari, Finland

**Technical information** 230V,50Hz, 0,75A, 83W, 3200 r/min ( ECo110 FLOW, ECo125 FLOW)  
230V,50Hz, 0,75A, 83W, 2580 r/min ( ECo160 FLOW)

**Other information** -

**The product is certified according to the following standard(s)** EN 60335-2-80:2003 + A1:2004 + A2:2009  
EN 60335-1:2012 + A11:2014 + A13:2017 + A1:2019 + A14:2019 + A2:2019

**Validity** This certificate is valid until 20 September 2024 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

**Date of issue**

**SGS Fimko Ltd**

**Signature**



Peter Fagerstedt  
Certification Manager



**Manufacturer**

VILPE Oy  
Kauppatie 9  
FI-65610, Mustasaari, Finland

**Manufacturing site**

VILPE Oy  
Kauppatie 9  
FI-65610, Mustasaari, Finland

**Directive information**

The certified product(s) fulfils requirements of mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

**Additional information**

This certificate replaces the previous certificate FI/40372/M1, dated 09 November 2020, due to addition of alternative motors.

**As shown in the Test Report(s) No(s):** 294583-1, 294583-1 Amendment 1, 294583-1 Amendment 2