



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2002636R1

Powered roof ventilator

Type designation: ECo110 FLOW, ECo125 FLOW, ECo160 FLOW

Certificate holder: VILPE Oy
Kauppatie 9
FI-65610, Mustasaari, Finland

The product complies with the standard(s): EN 60335-1:2012+A11+A13+A1+A14+A2
EN 60335-2-80:2003+A1+A2

Date of expiry: 20 September, 2024

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:  **Date:** 24 August, 2022

Leif Mattsson

APPENDIX:

Reference No. SE-S-2002636R1

Technical Data:

Type designation ECo110 FLOW, ECo125 FLOW, ECo160 FLOW
Rating 230V,50Hz, 0,75A, 83W, 3200 r/min (ECo110 FLOW, ECo125 FLOW)
230V,50Hz, 0,75A, 83W, 2580 r/min (ECo160 FLOW)
Trademark VILPE
Test Report 294583-1, 294583-1 A1, 294583-1 Amendment 2
Product information -

Manufacturing Sites:

VILPE Oy
Kauppatie 9
FI-656 10, Mustasaari, Finland

The instruction for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

This certificate is based on a certificate with ref. No. FI/40372/M2 dated 02 August 2022, issued by SGS Fimko Ltd according to the Nordic Certification Service Agreement.

This certificate replaces previously issued ref. No. SE-S-2002636 dated 18 November 2020. A new certificate has been issued due to addition of alternative motors.

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:



Date: 24 August, 2022

Leif Mattsson

