

Revision history

Release date	CU Firmware version	Changes
16.1.2023		First draft
27.2.2023		Added status registers
30.4.2023		Cleanup + some additions
16.8.2023		Updates
30.10.2023		Cleanup
5.11.2023		Minor changes to match phone app requirments better
2.12.2023		Floor limit moved to zone, naming in 20000 and 20001, limits in 0zz15/16 and 20000-20003
20.12.2023		Group vs. Custom reversed, week clock defaults + small fixes
11.1.2024		Floor limit activated + future reservations for RH
19.1.2024		OTA packet version number added
8.2.2024		Hop count and ota progress added
9.2.2024		CU and RU HW types added
11.3.2024		Zone helper update
15.5.2024		Floor max default + some fixes
14.6.2024		OZZ08 description corrected. Removed "future reservations" from dew point monitoring, since that has been implemented.
26.6.2024		Modbus slave ID range corrected

Definitions

CU	Control Unit	General term for Receiver. 8 channels.
CU8	8 channel Control Unit	A CU8 can act as stand-alone master, a slave in a network or as master which hosts a radio based network of CU's. It also supports Modbus RTU with access to the whole network.
RU	Room Unit	General term for Room Unit = Thermostat
Zone	Area controlled by one RU	Max 8 zones per CU. Up to 64 zones available in a network consisting of 8 CU's. Zone numbers will be assinged in order of pairing within each CU.
Master	Main CU in network	If only one CU is used, this will still be set as Master. The master is always CU1
Slave	Secondary CU in network	A slave will be assinged number CU2 ... CU8 in order of pairing

General information

Dialect Modbus RTU, RS485
Modbus address is adjustable between 1 - 63. Default: 1
The baud rate is adjustable to 9600, 19200, 38400, 115200 baud. Default: 38400
Parity is adjustable to: None, Odd, Even. Default: N
Stop Bits is adjustable to 1 or 2. Default: 1
Data Bits: 8
Note, a setpoint of the room temperature will have resolution of 0.5 degrees when the value sent to our room thermostat from the BMS sytem. (20.0, 20.5, etc.)

Address 4x	R/W	Register name	Min	Max	Default	Unit	Format	Description
System holding registers								
	1 R/W	Date Year	2010	2099	2023	year	uint16	
	2 R/W	Date Month	1	12	2	month	uint16	
	3 R/W	Date Day	1	31	17	day	uint16	
	4 R/W	Time Hour	0	23	0	h	uint16	
	5 R/W	Time Minute	0	59	0	min	uint16	
	6 R/W	Time Second	0	59	0	s	uint16	
	7 R/W	Time Week Day Number	1	7			uint16	1 is Monday
901	R	Modbus slave ID	1	63	1		uint16	Set with 6 LSB dip switches, read register only
902	R	Modbus baudrate	0	3	1		uint16	Set with 2 MSB dip switches. 0=115200 bits/s, 1=38400, 2=19200, 3=9600, read register only.
903	R/W	Modbus parity	0	2	0		uint16	0=None, 1=Odd, 2=Even
904	R/W	Modbus stop bits	1	2	1		uint16	
Zone (RU) holding registers								
Address: Replace ZZ with zone number Zone1=10, Zone2=11, Zone64=73								
OZZ01	R/W	Home Temp	0	400	210	0.1 deg C	uint16	Zones 1-8 belong to the CU1, Zones 9-16 to the CU2 and so on. If all Zones of a CU are not used the remaining ones are skipped. For example 1st and 2nd RU in 1st CU are Zones 1 and 2, 3rd and 4th RUs in 2nd CU are Zones 9 and 10. 220 is 22 C
OZZ02	R/W	Away Temp	0	400	190	0.1 deg C	uint16	190 is 19C
OZZ03	R/W	RU operation mode	0	2	0		uint16	0=home, 1=away, 2=week clock
OZZ04	R/W	RU custom settings mode vs. group settings	0	1	1		uint16	0=group mode, 1=custom mode
OZZ05	R/W	RU Adaptivity	0	1	0		uint16	0=adaptivity off, 1=adaptivity on
OZZ06	R/W	RU fireplace mode	0	1	0		uint16	0=fireplace mode off, 1=fireplace mode on
OZZ07	R/W	RU bypass mode	0	2	0		uint16	0=bypass mode off, 1=bypass mode constantly activated, 2= bypass mode time 0=off - room temperature regulation, 1=floor - floor temperature regulation, 2=combi mode - room temperature regulation with supervision for floor min and max
OZZ08	R/W	Extenal sensor	0	2	0		uint16	
OZZ09	R/W	RU identify	0	1	0		uint16	0=RU identify mode off, 1=RU identify mode on. Used to help pairing.
OZZ10	R/W	RU active state brightness	0	3	2		uint16	0=brightness level 1, 1=brightness level 2, 2=brightness level 3, 3=brightness
OZZ11	R/W	RU fireplace config 1	0	100	50	%	uint16	Fireplace mode percentage
OZZ12	R/W	RU fireplace config 2	0	255	16	h	uint16	Fireplace mode length: 1-99h, 255= continuous
OZZ13	R/W	Cooling allowed for zone	0	1	1		uint16	0=cooling not allowed, 1=cooling allowed. This can be used to block cooling in zone. If cooling is blocked actuator in that zone stays closed.
OZZ14	R/W	Selected week clock number	0	3	0		uint16	0=week clock not selected/programmed. 1=week clock 1, 2=week clock 2,
OZZ15	R/W	Floor min temperature	10	390	50	0.1 deg C	uint16	1-39C, default 5 C, in floor regulation mode also limit for temp setpoint
OZZ16	R/W	Floor max temperature	20	400	350	0.1 deg C	uint16	2-40C, default 35C, in floor regulation mode also limit for temp setpoint
OZZ17	R/W	Dew point monitoring	0	1	0		uint16	0=Dew point monitoring OFF, 1=Dew point monitoring ON.
OZZ18	R/W	Dew point temperature margin	0	300	10	0.1 deg C	uint16	Dew point temperature margin. Default 1 degree.

Three week clocks

[illegible]

1W059 R/W	Week-clock Saturday Event 5 setpoint	0	65535	65535 0.1 deg C	uint16	Thermostat target temperature i.e. setpoint 220=22.0 deg C. If event not defined 65535 0xFFFF.
1W060 R/W	Week-clock Sunday Event 1 time	0	34208	0 min	uint16	MSB=0 event not in use, MSB=1 event in use. LSBs=Time in minutes i.e. 22:25 =
1W061 R/W	Week-clock Sunday Event 1 setpoint	0	65535	65535 0.1 deg C	uint16	Thermostat target temperature i.e. setpoint 220=22.0 deg C. If event not defined 65535 0xFFFF.
1W062 R/W	Week-clock Sunday Event 2 time	0	34208	0 min	uint16	MSB=0 event not in use, MSB=1 event in use. LSBs=Time in minutes i.e. 22:25 =
1W063 R/W	Week-clock Sunday Event 2 setpoint	0	65535	65535 0.1 deg C	uint16	Thermostat target temperature i.e. setpoint 220=22.0 deg C. If event not defined 65535 0xFFFF.
1W064 R/W	Week-clock Sunday Event 3 time	0	34208	0 min	uint16	MSB=0 event not in use, MSB=1 event in use. LSBs=Time in minutes i.e. 22:25 =
1W065 R/W	Week-clock Sunday Event 3 setpoint	0	65535	65535 0.1 deg C	uint16	Thermostat target temperature i.e. setpoint 220=22.0 deg C. If event not defined 65535 0xFFFF.
1W066 R/W	Week-clock Sunday Event 4 time	0	34208	0 min	uint16	MSB=0 event not in use, MSB=1 event in use. LSBs=Time in minutes i.e. 22:25 =
1W067 R/W	Week-clock Sunday Event 4 setpoint	0	65535	65535 0.1 deg C	uint16	Thermostat target temperature i.e. setpoint 220=22.0 deg C. If event not defined 65535 0xFFFF.
1W068 R/W	Week-clock Sunday Event 5 time	0	34208	0 min	uint16	MSB=0 event not in use, MSB=1 event in use. LSBs=Time in minutes i.e. 22:25 =
1W069 R/W	Week-clock Sunday Event 5 setpoint	0	65535	65535 0.1 deg C	uint16	Thermostat target temperature i.e. setpoint 220=22.0 deg C. If event not defined 65535 0xFFFF.
Other global settings						
20000 R/W	Room regulation temp setpoint minimum	10	390	50 0.1 deg C	uint16	1-39C, default 5 C
20001 R/W	Room regulation temp setpoint maximum	20	400	400 0.1 deg C	uint16	2-40C, default 40 C
20002 R/W	Alarm min temperature	10	390	50 0.1 deg C	uint16	1-39C, default 5 C
20003 R/W	Alarm max temperature	20	400	400 0.1 deg C	uint16	2-40C, default 40 C
30000 R/W	System cooling mode	0	1	0	uint16	0=heating mode, 1=cooling mode

Address 3x	R	Register name	Min	Max	Default	Unit	Format	Description
System status registers								
	1 R	Global Pump State		0	1		uint16	0=off, 1=on
	2 R	Global Boiler State		0	1		uint16	0=off, 1=on
	3 R	Global Cooling State		0	1		uint16	0=off, 1=on
	4 R	Number of Room units in system		0	64		uint16	
	5 R	Number of Control units in system		1	8		uint16	
Section status registers. Section is CU number. Replace S with SECT1=CU1=1, SECT2=CU2=2, SECT8=CU8=8								
								bit 0 = Zone error, bit 1 = CU communication timeout, bit 2 = RFLU communication error, bit 3 = actuator fuse blown error.
	00S01 R	CU alarms					uint16	
	00S02 R	Setback switch state		0	1		uint16	0=switch open, 1=switch closed
	00S03 R	Heating/cooling switch state		0	1		uint16	0=switch open, 1=switch closed
	00S04 R	Section link quality		0	100	%	uint16	
	00S05 R	CU Software version					uint16	major.minor
	00S06 R	CU serial number LSB 16 bits					uint16	
	00S07 R	CU serial number MSB 16 bits					uint16	
	00S08 R	Zone number that uses actuator 1					uint16	0=none, 1-8=zone
	00S09 R	Zone number that uses actuator 2					uint16	0=none, 1-8=zone
	00S10 R	Zone number that uses actuator 3					uint16	0=none, 1-8=zone
	00S11 R	Zone number that uses actuator 4					uint16	0=none, 1-8=zone
	00S12 R	Zone number that uses actuator 5					uint16	0=none, 1-8=zone
	00S13 R	Zone number that uses actuator 6					uint16	0=none, 1-8=zone
	00S14 R	Zone number that uses actuator 7					uint16	0=none, 1-8=zone
	00S15 R	Zone number that uses actuator 8					uint16	0=none, 1-8=zone
	00S16 R	Bypass currently active in actuators					uint16	bit 0=actuator 1...bit7=actuator 8, 0=inactive, 1=active
	00S17 R	Section data has been synced					uint16	0=no, 1=yes
	00S18 R	Incoming water temperature	-32768	32767		0.1 deg C	int16	if no sensor present return -32767
	00S19 R	Outcoming water temperature	-32768	32767		0.1 deg C	int16	if no sensor present return -32767
	00S20 R	NC/NO switch state		0	1		uint16	0=NC Normally Closed, 1=NO Normally Open
	00S21 R	OTA packet SW version					uint16	major.minor
	00S22 R	CU HW type		0	65535		uint16	1=CU8
								Zones 1-8 belong to the CU1, Zones 9-16 to the CU2 and so on. If all Zones of a CU are not used the remaining ones are skipped. For example 1st and 2nd RU in 1st CU are Zones 1 and 2, 3rd and 4th RUs in 2nd CU are Zones 9 and 10.
Zone (room) status registers. Replace ZZ with zone number ZONE1=10, Zone2=11, Zone64=73								
	OZZ01 R	RU SW version				major.minor	uint16	
	OZZ02 R	Room temperature	-32768	32767		0.1 deg C	int16	room sensor error return -32767
	OZZ03 R	Floor temperature	-32768	32767		0.1 deg C	int16	if no sensor present return -32767
	OZZ04 R	Battery level		0	100	%	uint16	
	OZZ05 R	Link Quality		0	100	%	uint16	
	OZZ06 R	Zone is defined in CU		0	1		uint16	0=no, 1=yes
	OZZ07 R	Regulation output		0	100	%	uint16	PI regulation output

0ZZ08 R	Zone Alarms	0	65535		uint16	bit 0=room sensor error, bit 1=RU-CU communication error, bit 2=floor sensor error, bit 3=Battery low, bit 4=connected CU actuator fuse blown, bit 5=dew point limitation error (either problem with RH or outgoing water temp)
0ZZ09 R	Heat Status	0	1		uint16	0= no heating, 1=heating active
0ZZ10 R	Current setpoint in use	0	400	0.1 deg C	uint16	220 is 22 C. This shows currently active setpoint, coming either from home, away or schedule mode
0ZZ11 R	Relative humidity	0	100	%	uint16	Relative humidity if RH sensor present. If sensor not present return 65535.
0ZZ12 R	Zone limits	0	65535		uint16	bit 0=floor max limit activated (1), bit 1=floor min limit activated, bit 2=Dew point limit activated.
0ZZ13 R	Hop count to master				uint16	Number of RF hops to master e.g. 2 RU-REPE-CU
0ZZ14 R	OTA progress	0	100		uint16	
0ZZ15 R	RU HW type	0	65535		uint16	1=7seg, 2=knob

	Zone	ZZ in register	
CU1	C1.1	1	10
	C1.2	2	11
	C1.3	3	12
	C1.4	4	13
	C1.5	5	14
	C1.6	6	15
	C1.7	7	16
	C1.8	8	17
CU2	C2.1	9	18
	C2.2	10	19
	C2.3	11	20
	C2.4	12	21
	C2.5	13	22
	C2.6	14	23
	C2.7	15	24
	C2.8	16	25
CU3	C3.1	17	26
	C3.2	18	27
	C3.3	19	28
	C3.4	20	29
	C3.5	21	30
	C3.6	22	31
	C3.7	23	32
	C3.8	24	33
CU4	C4.1	25	34
	C4.2	26	35
	C4.3	27	36
	C4.4	28	37
	C4.5	29	38
	C4.6	30	39
	C4.7	31	40
	C4.8	32	41

CU5	C5.1	33	42
	C5.2	34	43
	C5.3	35	44
	C5.4	36	45
	C5.5	37	46
	C5.6	38	47
	C5.7	39	48
	C5.8	40	49
CU6	C6.1	41	50
	C6.2	42	51
	C6.3	43	52
	C6.4	44	53
	C6.5	45	54
	C6.6	46	55
	C6.7	47	56
	C6.8	48	57
CU7	C7.1	49	58
	C7.2	50	59
	C7.3	51	60
	C7.4	52	61
	C7.5	53	62
	C7.6	54	63
	C7.7	55	64
	C7.8	56	65
CU8	C8.1	57	66
	C8.2	58	67
	C8.3	59	68
	C8.4	60	69
	C8.5	61	70
	C8.6	62	71
	C8.7	63	72
	C8.8	64	73